



THE MARYLAND-NATIONAL CAPITAL PARK AND PLANNING
COMMISSION
Department of Parks and Recreation
6600 Kenilworth Avenue Riverdale, Maryland 20737

August 2, 2021

For The Attention of All Proposers:

**RE: Invitation For Bid: B41-133
For Henson Creek Golf Course Bridge Replacement
1641 Tucker Road, Fort Washington, MD 20744**

Subject: Addendum Number Four (4)

The following information related to the above project is provided to all prospective Proposers:

1. The due date and time for the submissions of proposals REMAINS August 12, 2021 before 3:00 PM.
2. Transmitted herewith as Attachment #1, is the Revised Bid Form.2
3. The Revised Bid Form.2 REMOVED the word "painted" from the end of item #46. *Prefabricated steel bridge, 120' long, 12' wide, with safety railing and steel toe plate.*

The following are questions received and M-NCPPC responses.

Q1. Where is the Concrete Deck sheet mentioned in the General Notes on the last page of the plans?

A1. Please refer to the revised sheet S-2.00, issued with Addendum #3. The note was erroneous, and the sheet has been corrected and a revised sheet has been included with Addendum #3.

- Q2. Form J.8 asks for Contractor's information only, it does not ask for Subcontractor's information. Please clarify if this form is needed for all Subcontractors and provide revised form if needed.
- A2. Form J.8 – The Contractor Reference Form is required to evidence minimum qualifications identified in Section F., of the Special Conditions, letter e., pg 99. If sub-contractors will be used to fulfill any of the minimum qualifications, then Form J.8 must be submitted for the sub-contractor.
- Q3. Provide planting schedules and their locations on plans for items 51, 52, 53.
- A3. Please see sheet 3.10 of the approved Final Erosion & Sediment Control plans. The initial plan set did not include this information. They have since been included as approved green stamp plans.
- Q4. Provide concrete deck sheet as mentioned on note 3, sheet 22.
- A5. Please refer to the revised sheet S-2.00. The note was erroneous, and the sheet has been corrected and a revised sheet has been included with the addendum.
- Q6. Provide clear description, details and specifications for item 43 Impervious pavement, includes base.
- A6. Please see sheet C-1.01 "Site Details" for paving specification for new bridge tie ins.
- Q7. Provide clear description, details and specifications for item 44 Asphalt pavement, includes base Steel Bridge.
- A7. Please see sheet C-1.01 "Site Details" for paving specification for new bridge tie ins.
- Q8. Will General Contractor be required to submit Form J.8 – "Contractor Reference Questionnaire Form" for all Subcontractors included in the bid? Many subcontractors are not selected until last minute and may not have Form J.8 included with their quote.

A8. See Answer #2 above.

Q9. The pedestrian bridge, as described on sheet S-2.00, General Note #2, is to be fabricated from “high-strength, low-alloy, enhanced atmospheric corrosion resistant” steel. This type of steel is also known as weathering steel and does not require painting or coating of any kind, unless noted as such in the project specifications. There are no notes on this particular sheet indicating that it needs to be coated, however in the bid form, the item for the bridge (#46) describes the bridge as being painted. Can you confirm that it does in fact need to be painted? If so, we’ll need to know if the base steel needs to be weathering steel or if it can be a plain carbon steel, which is more typical for painted structures. We’ll also need to know if the paint system needs to be a 2-coat or 3-coat system.

A9. Please find the Revised Bid Form.2 without the word “painted” in the bridge description. The reference was erroneous. This bridge is not planned for painting.

All other terms and conditions apply.

Proposers must acknowledge receipt of this amendment by:

1. Signing below and returning this letter with our proposal submittal; or
2. Indicating receipt of this Addendum by identifying Addendum Number and date.

Receipt Acknowledged by
Authorized Company Official

Lisa Buckmaster
Lisa Buckmaster
Procurement Specialist

END OF Addendum Four (4)